CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-1591:195 Page 1 of 2

CATEGORY: Control Units (High-Rise)

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243

Contact: Leon Newsome (941) 739-427 Fax (941) 739-4334

DESIGN: Model EST-2, EST-2R, EST2-6 and EST2-6R fire alarm control units. Non-coded; automatic,

manual, local, auxiliary, remote station, central station, proprietary, waterflow and sprinkler supervisory service. The system is modular in construction and can be expanded by adding

modules. System components:

2-CAB/240424 Enclosure

2-MCM/130290 Main Control Module
2-MCMN Main Control Module
2-PPS/130339 OEM Power Supply
2-LCD/130274 Display/Switch Module
2-LCX/130313 Expansion Loop

RPM/130090 Reverse Polarity Module

MTM/130127 Coder Module

IOP-3, -3A/130117 Isolated RS-232 Module 2-16R/130328-01 16 Red LED Annunciator 2-16Y/130328-00 16 Yellow LED Annunciator 2-16G/130328-02 16 Green LED Annunciator

2-16R8S/130328-06 16 Red LED/8 Switch Annunciator 2-8RYS/130328-05 8 Red/Yellow LED/8 switch Annunciator

2-8RY/130328-03 8 Red/Yellow LED Annunciator 2-12R4Y/130328-04 12 Red/4 Yellow LED Annunciator 2-16Y8S/130328-07 16 Yellow LED/8 Switch Annunciator

2-CTM/140378 City Tie Module

2-SAN-COM-R/240601 Remote Control Module

2-CMDN-C/240695, 1577 Annunciator

SAN-CPU Annunciator Module
2-CMDN/240600 Remote Annunciator
2-SMDN/240696 Remote Annunciator
2-SMDN-C/240697 Remote Annunciator
2-PPS-6 Power Supply
DL2 Dial Module

2-WB(R), 2-WBS(R) Enclosure 2-ACAB Audio Enclosure

2-SMK Smoke Detector Module APS8B Auxiliary Power Supply

11-02-2002

2-AAC Audio controller
2-MIC Paging Microphone
2-TEL Firefighters Telephone

2-WB3(R) Long Wallbox

2-WB7(R) Double Wide Wallbox

RACCR Remote Audio Closet Cabinet

SIGA-AA30, -AA50 Amplifier

SIGA-APS

2-MCD

2-WB3D

2-WB7D

RACCDR

Auxiliary Power Supply

Main Control Module

Door for 2-WB3

Door for 2-WB7

Door for RACCR

2-ISO RS-485 Isolator Module 2-DLM Data Line Monitor Module

2-WBD, -WBDR, -WBDSR Enclosure Door

2-WB3D/DF, -WB7D/DF Enclosure Door

PT1-S System Printer

PT1-P System Printer Parallel

2-LKF(R), 2-DKF(R) Trim Kit

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes &

ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit suitable for high rise applications when used with separately

listed compatible initiating and indicating devices.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm

Evacuation Signal as required per NFPA 72, 1999 Edition.

NOTE: 1. For *Fire Alarm Verification Feature*, the maximum retard/reset/restart period shall not exceed 30 seconds.

2. Formerly 7170-1388:220

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 17, 2003 Listing Expires June 30, 2004

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager